

REGIONAL WATER TESTING LAB, HOSHIARPUR

Government ITI, Jalandhar Road, Hoshiarpur
rwlhsp@gmail.com

TEST REPORT

Name & Address of Customer : M.G.I. Convent School Kallowal Academy, P.O. Passi Kandi, Dasuya, Hoshiarpur		Customer-Reference No.	No : 241 Dated : 27/04/2026
		Sample Submitted by	Jogeshwar Singh
		Date of Sample Receipt	02/05/2026
		Analysis Starting Date	02/05/2026
		Analysis completion Date	04/05/2026
Discipline : Chemical Testing, Bacteriological Testing		Group: Water	
ULR No.:		Sample Type :	Water
Test Report No.:	RWTLHSP/2627/00088	Date of Issue :	04/05/2026
Registration no.:	RWTLHSP/REG2627/00352	Condition of Sample :	Unsealed
Collection Point:	Private Submersible	Quantity/Type of Bottle:	1000 ml / Transparent Plastic Bottle
Scheme/Source:	Not Mentioned(Not Mentioned)	Location/Depth :	M.G.I. Convent School / NA
Village :	KALLOWAL	Habitation :	KALLOWAL
Block:	Dasuya	District :	Hoshiarpur
Latitude :	Not Mentioned	Longitude:	Not Mentioned

Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	6.59@25°C	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-2022) Electrometric Method
2	Colour	1	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 – 2018) (Second Revision)
4	Taste	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 8 – 2023)
5	TDS	107.0	500	2000	mg/l	IS 3025 (Part 16-2023) Gravimetric Method
6	Turbidity	BDL	1	5	NTU	IS 3025 (Part 10-2023) Nephelometric Method
7	T. Alkalinity(CaCO3)	84.42	200	600	mg/l	IS 3025 (Part 23-2023) Indicator Method
8	T. Hardness(CaCO3)	73.44	200	600	mg/l	IS 3025 (Part 21- 2009)(RA 2023) EDTA Method
9	Calcium(Ca)	16.35	75	200	mg/l	IS 3025 (Part 40-2024) EDTA Titrimetric Method
10	Magnesium(Mg)	7.93	30	100	mg/l	APHA (24th Ed.2023) Method: 3500-Mg+2 B By Calculation Method
11	Chloride(Cl)	10.07	250	1000	mg/l.	IS 3025 (Part 32-2025) Argentometric Method
12	Total Coliform(TC)	ND	Shall not be detectable in any 100 ml sample	No relaxation	---	IS 15185 Membrane Filtration Method
13	E-Coli	ND	Shall not be detectable in any 100 ml sample	No relaxation	---	IS 15185 Membrane Filtration Method

Continue on next page...

Reviewed and Approved By

Abhishek Joshi

Abhishek Joshi
Sr. Chemist
Authorized Signatory
For, Regional Water Testing Lab
Hoshiarpur

REGIONAL WATER TESTING LAB, HOSHIARPUR

Government ITI, Jalandhar Road, Hoshiarpur
rwtlhsp@gmail.com

To,

M.G.I. Convent School
Kallowal Academy, P.O. Passi Kandi, Dasuya, Hoshiarpur

No.: RWTLHSP/2627/00088 Dated : 04/05/2026

Subject : Testing Reports of Water Samples.

Reference: Your Letter/SRF No. 241 Dated: 27/04/2026

As per above cited subject and reference, Please find enclosed here with the report of 1 Water sample/s received on dated 02/05/2026. It is request to fill the attached feedback form and send it back to Regional Water Testing Lab, Hoshiarpur

D/A : Test Report



Authorized Signatory
For, Regional Water Testing Lab
Hoshiarpur